

DECLARATION OF PERFORMANCE

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

SCREW FITTINGS

are manufactured in accordance with the UNE EN 1254-4 standard and the working conditions are the following:

Nominal pressure	50 bar
Temperature range	-20°C up to 140°C

According to its technical features and materials, this series is intended to be used in:

- Drinking water and sanitary hot water.
- Water distribution network.
- Heating and air-conditioning systems
- Compressed air

This product has been certified by:

- Narodowy Instytut Zdrowia Publicznego with Hygienic Certificate (PZH) n° B-BK-60210-0627/21 issued on June 1st 2021.

VALVULAS ARCO S.L. Quality Control System is certified by **TÜV SÜD Management Service GmbH** with **ISO 9001:2015** and **ISO 14001: 2015** and by **Swiss Safety Center** with **ISO 45001:2018**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

November 9th, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager